

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

Audiga Building Material Jiangsu Co., Ltd.

8 Fuye Road, Huangtang, Xuxiake Town, Jiangyin City, Jiangsu, China

For the following product(s):

Vinyl Tile:

Stone Plastic Composite Flooring/SPC Flooring (Maximum thickness: 10mm),
Wood Plastic Composite Flooring/WPC Flooring (Maximum thickness: 10mm)

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

FloorScore®

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.0

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m³ (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-FS-05029

Valid from: July 1, 2019 to June 30, 2020



ISO/IEC 17065
Product Certification Body
#0821



A handwritten signature in black ink that reads "Stanley Mathuram".

Stanley Mathuram, PE, Vice President
SCS Global Services
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA